



Victoria Government Gazette

No. S 653 Wednesday 6 December 2023
By Authority of Victorian Government Printer

Occupational Health and Safety Act 2004

OCCUPATIONAL HEALTH AND SAFETY REGULATIONS 2017

Determination

This determination has been made by the Victorian WorkCover Authority (trading as WorkSafe Victoria) under regulation 6(1)(o) of the Occupational Health and Safety Regulations 2017.

This determination applies to the removal of high-rupturing capacity (HRC) fuses containing asbestos which are, or are reasonably likely to be, intact, including removal of the fuse carrier or fuse box when it is holding the fuse.

For the purposes of this determination, intact is in relation to the state of the mechanical integrity of the HRC fuse and means there is no breach of its exterior casing. The electrical integrity of the fuse is not relevant to the mechanical integrity.

The determination deems the above activity, when carried out at a workplace, an asbestos-related activity for the purpose of regulation 302(1) of the Occupational Health and Safety Regulations 2017.

This determination starts from the date of publication of this notice in the Government Gazette.

ADAM WATSON

Commander, Field Operations

for and on behalf of the Victorian WorkCover Authority
(trading as WorkSafe Victoria)

SPECIAL

ive

The *Victoria Government Gazette* is published by IVE Group Limited with the authority of the Government Printer for the State of Victoria

© State of Victoria 2023

This publication is copyright. No part may be reproduced by any process except in accordance with the provisions of the Copyright Act.

Address all enquiries to the Government Printer for the State of Victoria
Level 2, 1 Macarthur Street
Melbourne 3002
Victoria, Australia

How To Order



**Retail &
Mail Sales**

Victoria Government Gazette
Ground Floor, Building 8,
658 Church Street,
Richmond 3121



Telephone

03 8523 4601

email

gazette@ivegroup.com.au

Price Code A